FireSilx Artificial Bark BS EN 13501-1

Certification

Test: **BS EN 13501-1:2009**

Description: Fire classification of construction products and building

elements

Sample: Bespoke Tree Artificial Bark

Date Tested: 19/01/2016

Result: Passed - Class B, s2, d0

County of Classification: UK & Europe

Test Report No: FR035

Mark Nesbitt

FireSilx Managing Director



Fire retardant properties of all FireSilx products are guaranteed for life

Any duplications, copy in part or in full, is a breach of intellectual property rights and will constitute as a copyright infringement. Copyright © FireSilx Company No SC156162